

GENERAL REQUIRMENTS FOR DECORATIONS, FURNISHINGS & INTERIOR FINISH

	UPHOLSTERED FURNITURE Chairs, Benches, Couches & including Solid Plastic /Molded Seating	REUPHOLSTERED FURNITURE	DRAPERIES & DECORATIVE MATERIAL Curtains, Drapes Banners,*Foam Cellular Boards	FABRIC/VINYL WALLCOVERING & PANEL SYSTEMS	FLOORCOVERING	TENTS & TEMPORARY ENCLOSURES	MATTRESSES & MATTRESS PRODUCTS
STANDARDS/ REGULATION	BFD IX-10 F. P.C. ARTICLE IX	BFD IX-10 F.P.C. ARTICLE IX	FIRE PREV. CODE ARTICLE IX	FIRE PREV. CODE ARTICLE IX MASS STATE BLDG CODE, 5TH EDITION, 780 CMR SECTION 922.0	MASS STATE BLDG CODE, 5TH EDITION, 780 CMR SECTION 922.0	FIRE PREV. CODE TEMPORARY ENCLOSURE SECTION 31.05 TENTS-SECTION 7.12(a)	MATTRESSES, PORTABLE MATTRESS, & MATTRESS PADS, 4/3/96
TEST METHOD	BFD IX-10 CA TB 133 ASTM E1537 (Based on Product Fire Test)	BFD IX-10 BFD IX-1 *	BFD IX-1	BFD IX-1 ASTM E 84	ASTM E648	BFD IX-1	BFD IX-11
REGULATED OCCUPANCIES	A=ASSEMBLY B=BUSINESS E=EDUCATIONAL I=INSTITUTIONAL M=MERCANTILE in public areas & offices R=RESIDENTIAL excluding R-3, R-4				only regulated in corridors, exitways, stairways and lobbies occupancies use groups provided on separate chart		Hospitals Nursing Homes College Dormitories Hotels
BFD REQUIREMENTS	LABEL DESIGNATED BY CA TB 133 MUST BE AFFIXED TO ALL SEATING PRODUCTS. MANUFACTURER MAY BE REQUIRED TO SUBMIT TEST REPORT TO DEMONSTRATE COMPLIANCE.	USE EXISTING FOAM OR FR FOAM (Minimum CA 117). COVER FOAM WITH A BARRIER PRODUCT OR LAMINATE BARRIER TO THE COVER FABRIC. ALL FIBERFILL MUST BE PROTECTED BY A BARRIER PRODUCT. FR TREATMENT OF COVER FABRICS IS NOT REQUIRED. * POLYOLEFIN & NYLON FABRICS MUST BE LAMINATED WITH BARRIER PRODUCT. SUBMIT A 12" X12" SAMPLE FOR TESTING. *YOU MAY BE REQUIRED PRODUCT APPROVAL.	SUBMIT A 12" X12" FROM ACTUAL YARDAGE TO BE USED. CERTIFICATE OF FLAME RETARDANT FINISH SHALL BE SUBMITTED.	SUBMIT A 12" X12" SAMPLE (Cover Fabric) FOR TESTING. SUBMIT ACTUAL FIRE TEST REPORT. ALL FIBERFILL SHALL BE ENCASED WITH A BARRIER PRODUCT. CLASS 1 (0-25 fs)	SUBMIT ACTUAL FIRE TEST REPORT. CARPET AND UNDERLAYMENT MUST BE TESTED TOGETHER.	TEMP. ENC.: SUBMIT 1 SQ. YD. FOR TESTING. (also obtain a permit for Asbestos Removal with Fire Prev. Div.) TENTS: SUBMIT 12" X12" SAMPLE FOR TESTING. (also obtain a permit to erect a tent with the Fire Prev. Div.)	IX-11; FOR MATTRESS, BOX SPRINGS AND BEDDING.
BFD RESTRICTIONS	NO EXEMPTIONS FOR AUTOMATIC SPRINKLERS. NO EXCLUSIONS FOR LIMITED SEATING CAPACITY IN ANY AREA.		SHALL NOT BE PLACED TO OBSTRUCT THE USE OF AN EXIT, EXIT ACCESS, OR EXIT DISCHARGE. *Contact BFD for restrictions and regulations.	RESTRICTS THE USE OF TEXTILE FABRICS ON THE WALLS/CEILING OF ELEVATOR CABS.	RESTRICT THE USE OF CARPET ON WALLS/CEILING SURFACES, SEATING PRODUCTS,OR AS DECORATIVE MATERIAL USE.		

NOTE: Formal Application forms must be submitted and a Permit obtained prior to the installation of Products. Failure to supply complete information and adequate sample material for testing will result in delays in evaluation. All applications must be signed by submitter. Specific requirement are provided in the regulations.